

Verification Certificate

This is to certify that:

Cableduct Limited
30 Selhurst Road
London
Greater London
SE25 5QF
United Kingdom

Holds Certificate Number:


VC 725047

In respect of:

BS EN 60670-23:2008 Boxes and enclosures for electrical accessories for household and similar fixed electrical installations

— Part 23: Particular requirements for floor boxes and enclosures.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2020-06-22

Latest Issue: 2020-06-22

Effective Date: 2020-06-22

Expiry Date: 2021-06-21

Page: 1 of 3

...making excellence a habit.™

Verification Certificate

No. VC 725047

**BS EN 60670-23:2008:
2000 series Floor Box**

Composite construction, for installation in floors subjected to dry treatment, -5 °C to +60 °C, removable lid.

Report number(s): 3152342 (GJW2020-2028BSI)

Part code	Compartments	Plug space (mm)	Wiring space (mm)	Base box depth	Floor cut-out (mm)	Feed type
SBOX-2355C	3	28-31	22	55	307 x 244	Conduit (20 mm) for cavity or screed
SBOX-2355U3	3	28-31	22	55	307 x 244	In screed trunking U3 – 225 x 25 mm
SBOX-2355FF	3	28-31	22	55	n.a.	Flush screed trunking FF12 330 x 55 mm
SBOX-2365C	3	30-34	29	65	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed
SBOX-2365U3	3	30-34	29	65	307 x 244	In screed trunking U3 - 225 x 25mm
SBOX-2365FF	3	30-34	29	65	n.a.	Flush screed trunking FF13 330 x 65 mm
SBOX-2385C	3	35-41	39	85	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed
SBOX-2385U3	3	35-41	39	85	307 x 227	In screed trunking U3 – 225 x 25 mm
SBOX-2320C	3	63-69	44	120	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed
SBOX-2455C	3	28-31	22	55	307 x 244	Conduit (20 mm) for cavity or screed
SBOX-2465C	4	30-34	29	65	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed
SBOX-2465U3	4	30-34	29	65	307 x 244	In screed trunking U3 – 225 x 25 mm

First Issued: 2020-06-22

Latest Issue: 2020-06-22

Effective Date: 2020-06-22

Expiry Date: 2021-06-21

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Verification Certificate

No. VC 725047

2000 series Floor Box (continued)

Part code	Compartments	Plug space (mm)	Wiring space (mm)	Base box depth	Floor cut-out (mm)	Feed type
SBOX-2465FF	4	30-34	29	65	n.a.	Flush screed trunking FF15 440 x 65 mm
SBOX-2485C	4	35-41	39	85	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed
SBOX-2485U3	4	35-41	39	85	307 x 227	In screed trunking U3 – 225 x 25 mm
SBOX-2420C	4	63-69	44	120	307 x 227	Conduit (20 mm & 25 mm) for cavity or screed

First Issued: 2020-06-22

Latest Issue: 2020-06-22

Effective Date: 2020-06-22

Expiry Date: 2021-06-21

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.